

Contaminanti eliminati de statile de osmoza inversa casnice:

Filtrele cu Osmoza Inversa folosesc o membrana compozit TFC ce elimina din apa urmatarii contaminanti

Cations	
Substance	% REJECTION TFC*
Sodium	99
Calcium	99
Magnesium	99
Potassium	98
Iron	99
Manganese	99
Aluminum	99
Ammonium	97
Copper	99
Nickel	99
Zinc	99
Strontium	99
Cadmium	99
Silver	98
Mercury	98
Barium	99
Chromium	99
Lead	99

Anions	
Chloride	99
Bicarbonate	98
Nitrate	97
Fluoride	98
Silicate	98
Phosphate	99
Chromate	99
Cyanide	95
Sulfate	99
Thiosulfate	99
Ferro cyanide	97
Bromide	98
Borate	50
Arsenic	99
Selenium	99

Biological & Particulate Removal	
Bacteria	>99
Protozoa	>99
Ameobic Cysts	>99
Giardia	>99
Asbestos	>99
Sediment/Turbidity	>99

% ratele de respingere sunt numai estimari si depind de mai multe variabile, cum ar fi concentratiile de contaminanti din sursa de apa.